

**ENERGY ENGINEERING  
ANALYSIS PROGRAM  
AT  
WATERVLIET ARSENAL, NY**




**VOLUME I: EXECUTIVE SUMMARY**

**FINAL REPORT**

**19971023 098**

**NOVEMBER 1984**



**PREPARED BY**

**PRC SYSTEMS SERVICES**

**151 CENTER STREET**

**CAPE CANAVERAL, FLORIDA 32920**

**UNDER**

**NORFOLK EEAP CONTRACT DACA-65-80-C-0014**




DEPARTMENT OF THE ARMY  
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS  
P.O. BOX 9005  
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO  
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.  
Distribution A. Approved for public release.

  
Marie Wakefield,  
Librarian Engineering

# EXECUTIVE SUMMARY

## TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.	INTRODUCTION . . . . .	1
2.	EXISTING ENERGY CONSUMPTION . . . . .	1
2.1	Basewide Energy Consumption . . . . .	1
2.2	Historical Fuel Consumption . . . . .	2
2.3	Building Type: Source Energy Consumption . . . . .	2
2.4	Typical Building Energy Consumption . . . . .	6
3.	INCREMENT A - BUILDINGS AND PROCESSES . . . . .	6
3.1	ECIP Projects Developed . . . . .	6
3.1.1	Architectural/Structural/Destratification Modifications . . . . .	15
3.1.2	Solar DHW Heaters in Family Housing . . . . .	16
3.1.3	Heating, Ventilating, and Air-Conditioning Systems Modifications . . . . .	16
4.	INCREMENT B - UTILITIES, DISTRIBUTION SYSTEMS, AND ENERGY MON- ITORING AND CONTROL SYSTEM . . . . .	17
4.1	ECIP Projects Developed . . . . .	18
4.1.1	Modifications for EMCS . . . . .	18
4.1.2	Electrical Distribution System Modifications . . . . .	18
5.	INCREMENT C - RENEWABLE ENERGY SOURCES: SOLAR AND BIOMASS . . . . .	18
6.	INCREMENT D - COGENERATION . . . . .	18
7.	INCREMENT E - CENTRAL BOILER PLANT PROJECTS . . . . .	19
8.	INCREMENT F - FACILITIES ENGINEER CONSERVATION MEASURES . . . . .	19
9.	INCREMENT G - NONQUALIFIED INCREMENTS A AND B PROJECTS . . . . .	19
9.1	Increment G Projects Developed . . . . .	19
9.1.1	Weatherization Modifications . . . . .	19
9.1.2	Weatherization Modifications in Family Housing . . . . .	20
9.1.3	HVAC Modifications: Retrofit Electrostatic Precipitators . . . . .	20
10.	ENERGY PLAN . . . . .	21
10.1	Energy Usage per Square Foot . . . . .	21

# LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1	Historical Fuel Consumption . . . . .	3
2	Administration, Operations, and Training Energy Consumption . .	7
3	Storage and Warehouse Energy Consumption . . . . .	8
4	Theaters, Clubs, Recreation Centers, and Bowling Energy Consumption . . . . .	9
5	Mess Hall, Snack Bar, Cafeteria, and Restaurant Energy Consumption . . . . .	10
6	Barracks and BOQ Energy Consumption . . . . .	11
7	Gas Station, Garage, Motor Pool, and Shops Energy Consumption .	12
8	Family Housing Energy Consumption . . . . .	13
9	Other Energy Consumption . . . . .	14
10	EEAP Project Summary . . . . .	22

## 1. INTRODUCTION

This is the Corrected Final Report on Increments A, B, C, D, E, and G of the Energy Engineering Analysis Program (EEAP) at Watervliet Arsenal (WVLT). This project has been conducted under the Norfolk District, Corps of Engineers Contract No. DACA 65-80-C-0014, by PRC Systems Services, Cocoa Beach, FL.

During Increments A and B, five modification projects were recommended for funding under the Energy Conservation Investment Program (ECIP). Increment G resulted in three recommended projects and Increment E determined the feasibility of a new, coal-fired central steam plant. Studies conducted during Increments C and D concluded that none of the proposed work was economically feasible under applicable guidelines.

## 2. EXISTING ENERGY CONSUMPTION

Actual energy consumption at WVLT was determined from electricity billings and from fuel oil delivery records. Costs were taken from contracts and service agreements that were in force at the times the various increments were undertaken.

### 2.1 BASEWIDE ENERGY CONSUMPTION

Using conversion factors specified in the Army Facilities Energy Plan and prices in effect during the year, the following summarizes the total energy picture for fiscal year (FY) 82.

<u>Fuel</u>	<u>Consumption</u>	<u>Dollars</u>	<u>Source Energy Units</u>
Electricity	40,581,940 kWh	\$2,241,174	470,751 MBtu
Fuel Oil No. 2	193,662 gallons	247,887	26,861 MBtu
Fuel Oil No. 6	2,462,992 gallons	<u>2,677,165</u>	<u>368,685 MBtu</u>
		\$5,166,226	866,297 MBtu

## 2.2 HISTORICAL FUEL CONSUMPTION

Table 1 shows the historical record of fuel consumption from FY 75 through FY 82 and projected consumption for the future. The projection assumes that energy conservation measures recommended during this contract will have been completed and that the other factors (including base mission) remain constant. Not included are the anticipated effects of Increment E recommendations since the goal of that increment is not energy conservation, but rather cost reduction and conversion to a more plentiful and secure fuel.

## 2.3 BUILDING TYPE: SOURCE ENERGY CONSUMPTION

Buildings were grouped into 10 categories for the purpose of this study. Using FY 80 as the base year, the building groups were modeled on the computer to determine the relative consumption of each category. The following listing summarizes the results.

<u>Group</u>	<u>Title</u>	<u>Area (ft<sup>2</sup>)</u>	<u>Consumption MBtu</u>
I	Admin, Op, Trng	212,100	31,000
II	Stor, Whse	132,000	74,500
III	Rec, Clubs, Centers	3,800	1,100
IV	Mess Halls, Eating Estab	12,400	1,200
V	Clinic	0	0
VI	Barracks, BOQ	2,900	300
VII	Stores, Banks, Lib, Chap, Mus	0	0
VIII	Svce Sta, Gar, Mot. P, Shops	1,033,600	203,400
IX	Family Housing	130,300	12,000
X	Other, Audited	102,800	32,400
-	Other, Unaudited, Fuel Oil <sup>1</sup>	---	64,100
-	Other, Unaudited, Electricity <sup>2</sup>	---	390,000

<sup>1</sup>In addition to the unaudited buildings, this item accounts for oil to be saved because of base-initiated projects, and that used for processes.

<sup>2</sup>In addition to note 1, this item includes outdoor lighting and all pumps, fans, machines, and other equipment not subject to energy conservation measures.

Table 1. Historical Fuel Consumption

## WATERVLIET ARSENAL

	OCT 74	NOV 74	DEC 74	JAN 75	FEB 75	MAR 75	APR 75	MAY 75	JUN 75	JUL 75	AUG 75	SEP 75	TOTAL FY 75
FUEL OIL #2 GAL	5087	8660	10138	10411	14392	9116	10588	6510	11446	2538	717	2858	82461
FUEL OIL #6 GAL	207719	270881	332862	352459	294529	334911	239919	113591	56611	30877	53768	59538	2347668
TOTAL KWH X 10 <sup>3</sup>	2533	2380	2839	2672	2381	2678	2747	2749	2834	2119	2693	2661	31287

	OCT 75	NOV 75	DEC 75	JAN 76	FEB 76	MAR 76	APR 76	MAY 76	JUN 76	JUL 76	AUG 76	SEP 76	TOTAL FY 76
FUEL OIL #2 GAL	6413	1172	10958	14803	14690	9448	7986	4121	5824	490	6848	2839	88823
FUEL OIL #6 GAL	124710	194635	362239	436254	323317	310573	186640	143461	57291	28472	45871	69312	2292775
TOTAL KWH X 10 <sup>3</sup>	2679	2257	2931	2646	2464	2838	2599	2398	2844	1892	2880	2653	30980

	OCT 76	NOV 76	DEC 76	JAN 77	FEB 77	MAR 77	APR 77	MAY 77	JUN 77	JUL 77	AUG 77	SEP 77	TOTAL FY 77
FUEL OIL #2 GAL	6223	6316	14911	16550	24019	11398	5164	5040	4975	126	2645	20197	117564
FUEL OIL #6 GAL	216288	302413	394415	428267	331771	260558	186059	111948	62702	30952	37884	80174	2442731
TOTAL KWH X 10 <sup>3</sup>	2432	2847	2875	3084	2729	3022	2845	3030	3133	1995	3554	3496	35040

Table 1. Historical Fuel Consumption (cont)

WATERVLIET ARSENAL

	OCT 77	NOV 77	DEC 77	JAN 78	FEB 78	MAR 78	APR 78	MAY 78	JUN 78	JUL 78	AUG 78	SEP 78	TOTAL FY78
FUEL OIL #2 GAL	6150	12154	19195	12453	24178	10189	5865	7935	9914	168	41278	17389	129868
FUEL OIL #6 GAL	197459	255805	319279	393679	353385	432557	257540	131241	69406	38008	39530	41583	2559472
TOTAL FUEL X 10 <sup>3</sup>	3249	3369	3421	3558	3015	3586	3111	3493	2680	3593	2497	3302	38927

	OCT 78	NOV 78	DEC 78	JAN 79	FEB 79	MAR 79	APR 79	MAY 79	JUN 79	JUL 79	AUG 79	SEP 79	TOTAL FY79
FUEL OIL #2 GAL	5193	3618	24815	21362	11504	50162	39265	3064	19952	28800	32422	43378	288125
FUEL OIL #6 GAL	226059	354396	285442	444486	435591	395390	227010	83775	58779	40975	46605	51367	2649875
TOTAL FUEL X 10 <sup>3</sup>	3127	3231	3574	3596	3747	3501	3545	3234	3460	3427	2595	3644	40980

	OCT 79	NOV 79	DEC 79	JAN 80	FEB 80	MAR 80	APR 80	MAY 80	JUN 80	JUL 80	AUG 80	SEP 80	TOTAL FY80
FUEL OIL #2 GAL	27667	30535	22882	50851	24198	30239	16719	33742	31861	30035	21558	30084	355371
FUEL OIL #6 GAL	154348	264477	251075	356328	314979	213442	165522	91171	56034	412351	416332	41235	2068597
TOTAL FUEL X 10 <sup>3</sup>	30915	36066	3180	3355	36416	31641	2090	3122	3523	3184	2628	3283	38875



Table 1. Historical Fuel Consumption (cont)

	OCT 80	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	TOTAL
FUEL OIL #2 GAL	24188	24333	23730	50851	29200	28750	15800	28545	26670	25905	18009	24120	320,101
FUEL OIL #6 GAL	197716	263150	387607	356328	309894	325843	197621	96739	49066	22878	43247	55178	2,035,267
ELECT. KWH X 10 <sup>3</sup>	3065	3050	3520	3353	3727	3186	3274	3316	3282	3043	2775	3371	38,960

	OCT 81	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	TOTAL
FUEL OIL #2 GAL	16005	17328	18918	27110	22109	35245	7809	5880	6909	7246	8917	20186	193,662
FUEL OIL #6 GAL	197509	247064	347460	505440	338873	323465	247693	78756	52563	24970	48164	51035	2,462,992
ELECT. KWH X 10 <sup>3</sup>	3101	3131	3274	3491	3340	3340	3390	3411	3631	3520	3302	3650	40,582

PROJECTED

	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	TOTAL
FUEL OIL #2 GAL	15600	16900	18500	26600	21700	34900	7400	5500	6500	6850	8500	18966	187,916
FUEL OIL #6 GAL	123395	154355	217079	315778	211714	202087	154748	49203	32839	15600	30092	31885	1,538,775
ELECT. KWH X 10 <sup>3</sup>	3011	3041	3179	3390	3244	3243	3292	3312	3526	3418	3206	3544	39,406

## 2.4 TYPICAL BUILDING ENERGY CONSUMPTION

Tables 2 through 9 show the consumption of energy for heating, cooling, and lighting for individual buildings (or zones of buildings). The arrangement of the buildings is by the categories listed in 2.3. (Note: Lighting energy is measured at the site; heating and cooling energy is measured at the sources.)

## 3. INCREMENT A - BUILDINGS AND PROCESSES

The following measures were investigated in detail during Increment A. Those in the column on the left did not meet ECIP criteria or were rejected for other reasons. Those on the right have been incorporated into one or more ECIP project packages.

Exterior Wall Insulation	Interior Wall Insulation
Domestic Hot Water (DHW) Timeclocks	Exterior Roof Insulation
DHW Temperature Setback	Interior Roof Insulation
Personnel Door Weather Stripping	Ceiling Insulation
Bay Door Weather Stripping	Underfloor Insulation
Interior Lighting	Basement Wall Insulation
Sensible Heat Economizers	Window Treating (including Weather Stripping)
Pipe/Duct Insulation	Destratification Fans
	Solar DHW
	Condenser Heat Recovery
	Exhaust Air Heat Recovery
	Outside Air Economizer

### 3.1 ECIP PROJECTS DEVELOPED

The following paragraphs describe the projects that have resulted from the Increment A portion of the study. The effects of the projects are summarized in section 10.

Table 2. Administration, Operations, and Training Energy Consumption

## WATERVLIET ARSENAL

GROUP: I	TITLE: ADMIN. OP. TR	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
				TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P10A		5250	REPRODUCTION	287	63	54.7	10	3	1.9	19	3.6
P10B		3091	ADP	111	26	35.9	273	59	88.3	72	23.3
P10C		1790	OFFICE	111	29	62.0	0	0	0	2	1.1
P10D		58659	OFFICE	2819	739	48.1	0	0	0	485	8.3
P24		11400	ADMIN	1016	225	89.1	0	0	0	95	8.3
P40C		6314	SECURITY	664	147	105.2	0	0	0	91	14.4
P40D		3820	ADMIN	554	119	145.0	0	0	0	14	3.7
P40E		2882	REPRODUCTION	609	136	239.1	11	4	3.8	16	5.6
P40F		4957	PERSONNEL	960	207	193.7	0	0	0	79	15.9
P40I		20889	ADMIN	4464	996	213.7	0	0	0	178	8.5
P40J		2157	CONF ROOM	152	33	70.5	1	0	0.5	2	0.9
P40J		378	OFFICE	120	26	317.5	1	1	2.7	7	18.5
P40L		14716	OFFICE	3271	718	222.3	0	0	0	162	11.0
P40M		13564	OFFICE	1609	355	118.6	0	0	0	57	4.2
P40N		6846	ADMIN	1106	240	161.8	0	0	0	0	0
P40R		3193	ADMIN	595	131	186.3	18	5	5.6	2	0.6
P40S		13672	ADMIN	2061	451	150.7	0	0	0	0	0
P44A		30000	GAGE BLDG	2047	621	94.9	34	13	1.1	343	11.4
P115B		2300	COMPUTER	568	108	247.0	164	42	71.3	56	24.3
P135B		4173	OFFICE	352	95	84.4	0	0	0	36	8.6
P145A		2000	OFFICE	273	64	136.5	0	0	0	14	7.0

Table 3. Storage and Warehouse Energy Consumption

WATERVLIET ARSENAL

GROUP: 11	TITLE: STORAGE, WAREHOUSE	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
				TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P40G		2024	STORAGE	21	8	10.4	0	0	0	53	26.2
P120		93600	STORAGE	7711	1897	82.4	0	0	0	470	5.0
P130		28301	STOREHOUSE	63883	12842	2250.9	0	0	0	133	4.7
P1450		8000	WISE PROCESSING	531	114	66.4	0	0	0	49	6.1

Table 4. Theaters, Clubs, and Recreation Center Energy Consumption

WATERVLIET ARSENAL

GROUP: III TITLE: THEATERS, CLUBS, RECREATION CENTER

BUILDING	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
			TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P41	3/52	OFF CLUB	814	182	217.0	15	6	4.0	65	17.3

Table 5. Mess Hall, Snack Bar, Cafeteria, and Restaurant Energy Consumption

WATERVLIET ARSENAL

GROUP: IV	TITLE: MESS HALL, SNACK BAR, CAFETERIA, RESTAURANT	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION		
				TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)	
0106/000												
P21000 P400		11394 965	RESTAURANT PX	745 228	164 51	65.4 236.3	18 29	5 7	1.6 30.1	34 20	3.0 20.7	

Table 6. Barracks and BOQ Energy Consumption

WATERVLIET ARSENAL

GROUP: VI TITLE: BARRACKS, BOQ

BUILDING/ZONE	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
			TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P211H P221H	1528 1406	BOQ BOQ	173 140	39 30	113.2 99.6	4 1	2 0	2.6 0.7	0 0	0 0

Table 7. Gas Station, Garage, Motor Pool, and Shops Energy Consumption

WATERVLIET ARSENAL

GROUP: VII TITLE: GAS STATION, GARAGE, MOTOR POOL, SHOPS

BUDG./ZONE	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
			TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P15	22990	MOTOR POOL	4130	940	179.6	0	0	0	108	4.7
P20A	96000	SHOP	19027	4531	198.2	0	0	0	1046	10.9
P22B/H	8352	FIRE HOUSE	724	153	86.7	0	0	0	57	6.8
P23	10720	SHOP	2251	566	120.2	0	0	0	235	12.6
P25AA	61200	MFG SHOP	1591	360	26.0	0	0	0	1087	30.8
P25AB	61200	MFG SHOP	1559	352	25.5	0	0	0	1179	19.3
P25AC	61200	MFG SHOP	15296	3392	249.9	245	94	4.0	1423	23.3
P15A	169453	PILOT LINE BLDG	12446	2905	7.3	0	0	0	2423	14.3
P44B	1560	CONSTANT TEMP ROOM	202	59	180.8	30	9	19.2	2	1.3
P44C	2040	MACHINE ROOM	375	78	183.8	29	9	14.2	43	21.1
P110	224925	GUN SHOP	24697	6129	109.8	0	0	0	2985	13.3
P125	119340	MFG SHOP	16016	4094	134.2	0	0	0	1447	12.1
P135A	116645	MFG SHOP	59293	13916	317.7	0	0	0	2418	13.0



Table 8. Family Housing Energy Consumption

WATERVLIET ARSENAL

GROUP: IX	TITLE: FAMILY HOUSING	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
				TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P3		9740	SINGLE	609	145	62.5	0	0	0	30	3.1
P6		15970	DUPLEX	984	216	61.6	0	0	0	120	7.5
P8		11171	DUPLEX	737	163	66.0	0	0	0	84	7.5
P9		2260	DUPLEX	203	69	125.2	0	0	0	32	14.2
P19		9200	MULTI	603	140	65.5	0	0	0	69	7.5
P40A		2775	DUPLEX	1033	214	372.3	0	0	0	21	7.6
P40B		3064	DUPLEX	974	205	245.7	0	0	0	21	5.3
P460		2460	DUPLEX	166	42	67.5	0	0	0	18	7.3
P463		2016	SINGLE	137	30	68.0	0	0	0	15	7.4
P471*		9151	MULTI	396	98	43.3	0	0	0	68	7.4
P473*		13795	MULTI	602	149	43.6	0	0	0	103	7.5
P490		2730	SINGLE	254	58	93.0	0	0	0	21	7.7
P492		3008	DUPLEX	239	61	62.8	0	0	0	28	7.4
* REPRESENTS OTHER SIMILAR BUILDINGS											

\* REPRESENTS OTHER SIMILAR BUILDINGS

Table 9. Other Energy Consumption

WATERLILY ARSENAL

GROUP: X	TITLE: OTHER	FLOOR AREA	USE	HEATING CONSUMPTION			COOLING CONSUMPTION			LIGHTING CONSUMPTION	
				TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL (MEGA BTU)	PEAK MONTH (MEGA BTU)	BTU PER SQ FT (X1000)	TOTAL ANNUAL SITE (MEGA BTU)	BTU PER SQ FT (X1000)
P200		9600	OFFICE	960	250	10.0	0	0	0	216	22.5
P300		275	OFFICE	397	99	1443.6	34	12	123.6	131	476.4
P400		700	CLASSROOM	524	106	671.8	1	0	1.3	1	1.3
P400		649	REPRODUCTION	220	48	351.3	2	1	3.1	2	3.1
P115A		77700	WEAPONS DEV	16442	3462	211.6	114	60	1.5	649	8.4
			LAB								
P124		13776	LAB	1851	477	134.6	62	23	4.5	115	8.3

3.1.1 ARCHITECTURAL/STRUCTURAL/DESTRATIFICATION MODIFICATIONS. Work will consist of the following modifications to achieve improved energy conservation:

a. Wall Insulation.

- (1) R5 spray cellulose in buildings P25, P145  
R7 spray cellulose in buildings P25, P130  
R9 spray cellulose in buildings P25, P135
- (2) R9 F/G batts in building P15  
R13 F/G batts in building P135  
R15 F/G batts in buildings P10, P22, P125  
R17 F/G batts in building P41  
R19 F/G batts in buildings P10, P22, P40, P41, P44

b. Ceiling (Roof) Insulation.

- (1) R15 blown-in F/G in building P10  
R17 blown-in F/G in building P115
- (2) R9 lay-in F/G batts in building P44  
R13 lay-in F/G batts in building P44
- (3) R19 exterior IRMA-type roof system on building P20
- (4) R19 exterior insulation and new shingles on building P110

c. Floor/Basement Insulation.

- (1) R9 spray cellulose on basement walls in building P10
- (2) R9 F/G batts and furring on basement walls in building P23
- (3) R9 F/G batts and mesh under floor of building P22

d. Steam Pipe Insulation. R4 F/G in building P41

e. Window Treatment.

- (1) Double glazing on building P40
- (2) R14 insulating curtains on buildings P10, P22, P23, P24, P25, P40, P41, P44, P135
- (3) R19 dryvit-type panels on windows in buildings P120, P35, and P124
- (4) Translucent sandwich panels on buildings P125 and P130
- (5) R19 dryvit-type panels over 80 percent of translucent area, R11 translucent sandwich panels over 16 percent, and double pane glass over 4 percent of the existing translucent areas of building P135

f. Destratification. Fans in buildings P20, P110, P125, P35

NOTE

The terms dryvit, IRMA, fiberglass (or F/G) as used herein are intended as descriptive terms only. They are used for brevity and clarity to indicate acceptable types of modifications. Any equivalent product may be utilized.

3.1.2 SOLAR DHW HEATERS IN FAMILY HOUSING. Work will consist of installation of solar DHW heaters and appropriate plumbing and instrumentation in Rotterdam family housing. In addition, for buildings P471 and P475, a small weatherproof cover will be constructed to house the new hot water tank.

3.1.3 HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC) SYSTEMS MODIFICATIONS.

- a. Building 25 - Exhaust Air Heat Recovery. Work will consist of modifications to the existing first and second floor outside air intake and exhaust air systems to provide for a glycol pumparound system as follows:

- (1) Install air-to-glycol coils in north and south penthouse air intake
- (2) Install air-to-glycol heat recovery coils in the north and south general and toilet exhausts and the north elevator exhaust
- (3) Install a pump/control center and assorted glycol piping with insulation and suitable controls

b. Building 44 - Reduce Outside Air Intake. Work will consist of system modifications to HV-1 heating and ventilating system as follows:

- (1) Modify outside air intake duct for modulating dampers and air handler plenum to accommodate a return air duct with dampers
- (2) Install a return air duct system from the zone to HV-1
- (3) Modify controls and provide for damper modulation to control outside and return air in inverse proportions
- (4) Provide exhaust fan control modifications for minimum, medium, and maximum ventilation modes to operate in conjunction with HV-1 damper controls.

#### 4. INCREMENT B - UTILITIES, DISTRIBUTION SYSTEMS, AND ENERGY MONITORING AND CONTROL SYSTEM (EMCS)

The following measures were studied under Increment B:

- o Exterior lighting improvements
- o Steam/condensate system improvements
- o Electricity distribution system improvements
- o EMCS expansion

#### 4.1 ECIP PROJECTS DEVELOPED

This paragraph describes the projects that resulted from the Increment B portion of the study. The effects of the projects are summarized in 10.

4.1.1 MODIFICATIONS FOR EMCS. Buildings at WVLT are to be modified to achieve improved energy conservation. Install EMCS to control and minimize energy consumption. Useful management data will be reported to reduce labor requirements and report malfunctions as well as minimizing energy consumption during building nonuse hours.

Controls and sensors will be installed in buildings 10, 15, 20, 21, 23, 24, 25, 35, 40, 44, 110, 115, 120, 124, 125, 130, 135, and 136.

4.1.2 ELECTRICAL DISTRIBUTION SYSTEM MODIFICATIONS. Project consists of reducing the capacity of transformers by moving several existing transformers to different substations and by installing new transformers where requirements indicate.

#### 5. INCREMENT C - RENEWABLE ENERGY SOURCES: SOLAR AND BIOMASS

The feasibility of utilizing solar energy to supplement DHW heating, space heating, and a combination of water and space heating was analyzed during Increment C. No project in either the sample support building or in the sample family housing building proved acceptable under Increment C guidelines.

In the biomass portion of Increment C, the present economic viability of wood chips as a substitute fuel was determined. However, because of the uncertainty of supply and the potential volatility of the price, conversion to biomass as the primary fuel was not recommended. There are no other potential sources of renewable energy at WVLT.

#### 6. INCREMENT D - COGENERATION

Four different steam pressure/temperature situations were analyzed in order to determine the feasibility of electric cogeneration. In each case, a superheater was required and outlet steam conditions had to be equivalent to current heating

system supply conditions. In none of the cases was the life cycle cost as low as that of the status quo. Therefore, no projects are recommended.

#### 7. INCREMENT E - CENTRAL BOILER PLANT PROJECTS

Increment E resulted in the recommendation that a new, coal-fired, fluidized bed boiler plant be constructed near the site of the existing plant. Life cycle cost analysis (per applicable guidelines) clearly indicated the economic feasibility of coal firing versus oil.

#### 8. INCREMENT F - FACILITIES ENGINEER CONSERVATION MEASURES

No Increment F study was authorized under this contract.

#### 9. INCREMENT G - NONQUALIFIED INCREMENTS A AND B PROJECTS

Several projects that were originally considered under Increment A were re-analyzed under this increment. Those projects that are acceptable under Increment G criteria are described in the following paragraph. The effects of the projects are summarized in 10. One additional project, to combine the chilled water systems in buildings 115 and 120, was rejected again.

##### 9.1 INCREMENT G PROJECTS DEVELOPED

9.1.1 WEATHERIZATION MODIFICATIONS. Work will consist of the following modifications to improve energy conservation:

- a. Wall Insulation. R7 interior spray in buildings P110, P120, P124
- b. Lighting Modification. Replace fluorescent with high-pressure sodium in buildings 15 and 130
- c. Window Area Modification.

- (1) Replace deteriorated windows with same size double-glazed windows in building P10

(2) Replace deteriorated windows with double-glaze windows to fill 40 percent of window opening and fill 60 percent with insulated 6-in stud wall in building P40

(3) Cover deteriorated window area with 80 percent translucent sandwich panels and 20 percent double-glazed operable windows in building P110

9.1.2 WEATHERIZATION MODIFICATIONS IN FAMILY HOUSING. Work will consist of the following modifications to improve energy conservation:

a. Wall Insulation.

(1) R15 interior batt in building P21

(2) R17 interior batt in building P490

(3) R19 interior batt in building P22

b. Basement Wall Insulation. R11 spray cellulose in building P490

c. Insulating curtains in buildings P21, P22, P40, P460, P463, P490, P492

d. Shower flow restrictors in buildings P460, P463, P471, P472, P473, P474, P475, P490, P492

e. Automatic setback thermostats in buildings P460, P463, P470, P471, P472, P473, P474, P475

9.1.3 HVAC MODIFICATIONS: RETROFIT ELECTROSTATIC PRECIPITATORS. This project for building P125, Weld Shop, consists of modifications to the two existing exhaust systems to retrofit electrostatic precipitators for removal of contaminants and recirculation of a major percentage of the heated room air.



- a. Remove existing fan assemblies
- b. Install new fan/precipitator units
- c. Modify ducts and install new recirculated air supply ducts
- d. Install new modulating dampers in the outside air intake, exhaust, and recirculated air ducts with appropriate thermostatic controls

## 10. ENERGY PLAN

In FY 82, WVLT consumed 866,297 MBtu's of energy at a cost of over \$5 million. Implementation of all recommended projects except Increment E would reduce this consumption to 713,513 Btu's, which would cost less than \$4 million at comparable prices. Table 10 summarizes the recommended EEAP projects.

### 10.1 ENERGY USAGE PER SQUARE FOOT

The total area of buildings at WVLT is 1.7 million ft<sup>2</sup>. On a gross basis, the consumptions in Btu's in FY 82 and after implementation of recommended projects are:

	<u>FY 82</u>	<u>Future</u>	<u>Δ</u>
Electricity	276,912 Btu/ft <sup>2</sup>	268,888 Btu/ft <sup>2</sup>	8,024 Btu/ft <sup>2</sup>
Fuel Oil No. 2	26,861 Btu/ft <sup>2</sup>	26,064 Btu/ft <sup>2</sup>	797 Btu/ft <sup>2</sup>
Fuel Oil No. 6	<u>368,685 Btu/ft<sup>2</sup></u>	<u>230,339 Btu/ft<sup>2</sup></u>	<u>138,346 Btu/ft<sup>2</sup></u>
	672,458 Btu/ft <sup>2</sup>	525,291 Btu/ft <sup>2</sup>	147,167 Btu/ft <sup>2</sup>

This represents an overall reduction of almost 22 percent in total energy consumption.

Table 10. EEAP Project Summary

Project	Increment	DD 1391 Information					Energy Savings			
		Project Year	CWE \$1,000	E/C	B/C	P/B	Gallons FO #2	FO #6	kWh Electricity	Total MBtu
Architectural/Structural/ Destratification Modifications	A	1984	5,310	13.8	2.7	9.1	0	504,603	-183,621	73,404
Solar Assisted DHW	A	1984	383	2.4	0.4	18.9	2,588	0	48,621	923
HVAC Systems Mods	A	1984	346	21.3	4.1	6.2	0	50,812	-20,259	7,371
Install EMCS	B	1984	735	69.7	2.1	7.3	0	286,659	714,483	51,198
Elec Dist Syst Mods	B	1984	304	20.1	2.7	7.9	0	0	525,603	6,097
Weatherization Modifications	G	1984	1,728	6.6	1.7	14.9	0	72,964	34,914	11,327
HVAC Modification	G	1984	123	9.5	1.8	14.8	0	7,950	-1,552	1,172
Weatherization for Family Housing	G	1984	42	31.0	4.0	4.0	3,158	1,229	57,845	1,293
Totals							5,746	924,217	1,176,034	152,785